

**DISTRICT WATER TESTING LABORATORY**  
Public Health Engineering Department .P.H.E.D. Betul  
Near Satpuda club, Sadar, Betul (M.P.) 460001



TC-17158

**Test Report**

Location of performance Testing :- Laboratory		Not sampled by Lab		Unique Identification No.	DWTLBET
Nature of sample:- Drinking Water				Sender's letter Date	27/2/2026
To, Balaji International School Ghoradongri Dist.Betul (M.P.)	Sender letter no.	-		Collection date of Sample	27/2/2026
	Date of receiving sample	27/2/2026		LAB Ref. Date	27/2/2026
	LAB Ref. No	56		Date of analysis	28/2/2026
	Date of analysis started	27/2/2026		URL No. - TC171526000000053F	
	Quantity Of Sample	1 LTR		Environmental Condition - 23°C ± 5°C	
	Type of Sample	R.O. Water		Group - Water	
Discipline		Chemical			

**Sample details**

NO.	Particulars of Samples
1	R.O. Water Sample - Ghoradongri
2	-

**RESULTS**

No.	Characteristics	Unit	Test methods	BIS-10500:2012 Reaffirmed in .2023		Results	
				Desirable Limit	permissible Limit	1	2
				5	6		
1	2	3	4	5	6	1	2
1	Taste	-	IS:3025 ( part 7 ) : 2017	Aggregable	Aggregable	Agg	-
2	Colour in	CU	IS:3025 (part 4)visual comparison	5	15	6	-
3	Odour	-	IS:3025 (part 5) : 2018	Aggregable	Aggregable	Agg	-
4	Chloride as CL	mg/l	IS:3025 (part 32) : 1988	250	1000	40	-
5	Total Alkalinity as CaCO <sub>3</sub>	mg/l	IS:3025 (part 23) : 2023	200	600	90	-
6	Calcium as Ca <sup>++</sup>	mg/l	IS:3025 (part 40):2024	75	200	27.2	-
7	Magnesium as Mg <sup>++</sup>	mg/l	IS:3025 (part 46):2023	30	100	15.09	-
8	Total Hardness as CaCO <sub>3</sub>	mg/l	IS:3025 (part 21) : 2023	200	600	130	-
9	pH	pH scale	IS:3025 (part 11)	6.5 to 8.5	6.5 to 8.5	6.72	-
10	Fluoride as F	mg/l	IS:3025 (part 60/sec 1) : 2023	1.0	1.5	0.31	-
11	Sulphate as SO <sub>4</sub>	mg/l	IS:3025 (part 24/sec 1) :2022	200	400	15.3	-
12	Turbidity	NTU	IS:3025 (part 10) : 2023	1.0	5.0	1.2	-
13	Conductivity at 25°C	micromhos/cm	IS:3025 (part 14)	-	-	194	-
14	TDS	mg/l	IS:3025 (part 16) : 2023	500	2000	116	-
15	R.Chlorine	mg/l	IS:3025 (part26) : 2021	0.01	0.2	0.01	-

**Disclaimer**


- This report should not be produced partly or full without approval of signatory authority for legal purposes.
- It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under " acceptable " render the water not suitable , but still may be tolerated in the absence of an alternative source but the limit indicated under the "permissible limit in the absence of alternate source" in column 6, above with the sources will have to be rejected.
- The results refer only to tested sample and parameters tested.
- Samples will be stored for a period of 15 days from the date of issue of report.
- This lab dose not hold any responsibility for variation in results for samples kept on hold for want of clarification.

End of the test report .

Reviewed by

Mrs. Jany Panda  
Technical Manager

Issue No. 6 /DWTL/PHED/BET/ Issue Date - 02/03/2026



Authorised Signatory

Mr.Nilesh Chhatrapale  
Quality Manager

*(Signature)*  
अध्यक्ष

श्री बालाजी शिक्षा एवं  
समाज कल्याण समिती

**Principal**  
**Balaji International School**

**DISTRICT WATER TESTING LABORATORY**  
Public Health Engineering Department.P.H.E.D.  
Near Satpuda club, Sadar ,Betul (M.P.)460001

## Test Report

Nature of sample:-Drinking Water Sample/Others	Not sampled by Lab	Unique Identification No.	DWTLBET
TO, Balaji International School Ghoradongri Dist.Betul (M.P.)	Sander Letter No-	-	Sander Letter Date-
	LAB Ref. No	56	LAB Ref. Date
	Date of analysis started	27/2/2026	Date of analysis Completed
	Discipline	Bacteriological	Group
	Type of Sample	R.O. Water	Environmental Condition - 23°C ± 5°C
	Quantity Of Sample	200 ml	

## Sample details

NO.	Particulars of Samples
1	R.O. Water Sample - Ghoradongri
2	-

## RESULTS

## PARAMETERS PROPOSED FOR SCOPE



No.	Characteristics	Unit	Test methods	BIS-10500:2012 Reaffirmed in 2023		Results	
				Acceptable Limit	Permissible Limit	1	2
1	2	3	4	5	6		
2	Iron as Fe	mg/l	BIS:3025 part 53	1.0	1.0	0.1	-
3	Nitrate as NO3	mg/l	BIS:3025 part 34	45	45	8.9	-
4	Faecal Coliform (TTC)	per 100 ml	-	NIL		nil	-
5	Total Coliform	per 100 ml	-	NIL for treated water and water in		nil	-

## Disclaimer


1. This report should not be produced partly or full without approval of signatory authority for legal purposes.
2. It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under " acceptable " render the water not suitable , but still may be tolerated in the absence of an alternative source but the limit indicated under the "permissible limit in the absence of alternate source" in column 6, above with the sources will have to be rejected.
3. The results refer only to tested sample and parameters tested.
4. This lab dose not hold any responsibility for variation in results for samples kept on hold for want of clarification.

End of the test report

Report reviewed by

अध्यक्ष  
श्री बालाजी शिक्षा एवं  
समाज कल्याण समिती



Chemist  
District Water Testing Lab  
P.H.E.D. Betul(M.P.)



Principal  
Balaji International School

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY  
CONDITION CERTIFICATE**

No. 76Dated: 02/03/2026

It is certified that an inspection team headed by Nilesh Chhatrapale Chemist  
(Name of Officers with designation) from Public Health Engineering Department Betul


PHED inspected the Balaji International School, Sarni Road, Ghoradongri, Dist.- Betul, MP on 02/03/2026 and  
on the basis of Water Test Report (Attached) bearing no. 76 dated

02/03/2026 of URL No- TC171526000000053F Water Testing Lab Betul (PHED Lab)

certified that the Balaji International School, Sarni Road, Ghoradongri, Dist.- Betul, MP has safe drinking water  
facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation  
condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 06 Month's

Signature with seal



Name

Nilesh Chhatrapale  
Chemist  
Public Health Engineering Deptt.  
Betul (M.P.)

Designation

:- Chemist

Name & address of the office/Department: - Public Health Engineering Department  
Betul (M.P.)

To,  
Balaji International School,  
Sarni Road, Ghoradongri, Dist.- Betul, MP  
(Name and address of the institution)

Note: The certificate is to be issued by authorized officer / PHED Lab/local bodies

S  
Principal  
Balaji International School

Esareyam  
ASSISTANT ENGINEER  
Public Health Engg  
Sub-dn., Betul

Stanwar  
अध्यक्ष  
श्री बालाजी शिक्षा एवं  
समाज कल्याण समिति



Department of Finance , Government of Madhya Pradesh  
Acknowledgement Receipt for Online Tax Payment  
to M.P. State Government




TIN (Tax payment Identification Number) / Enrollment / Registration No.	-
Depositor/Dealer Name	Balaji International School
Address	Sarni Road , Sarni Main Road , Ghoradongri, Betul, Madhya Pradesh - 460443
District selected for Payment	Betul
Unique Registration Number (URN)	MPTURN020320260006637
Department and Office Name	Public Health Engineering, Balaji International School Ghoradongri
Challan Payment Period	2025-2026
Purpose	water Testing Charge

## Purpose Details

CRN	Assessment/ Concerning Period	Head of Account	Challan Identification Number (CIN)	Challan No.	Amount(Rs.)
MPT021502032026000013	2026-03-02 to 2026-03-02	0215-01-800-0000 ( Other Receipts )	SBIN0006159021502032026742391	051/9999999/0215/03/26/000011	1550.00

Total Amount(in figures)	1,550.00
Total Amount(in words)	One Thousand Five Hundred Fifty Rupees Only
Name and Code of the Bank	STATE BANK OF INDIA (2)
Bank Reference Number	CPAGKJLU08
Scroll No	74238
Scroll Date	02/03/2026
Date of Transaction / Time of Transaction (HH24:mm:ss)	02/03/2026 14:59:48
Transaction Status	Success

  
Principal  
Balaji International School

  
अध्यक्ष  
श्री बालाजी शिक्षा एवं  
समाज कल्याण समिती